Converting Volatile Organic Compounds to CO₂ and Water

Tang G. Lee

Faculty of Environmental Design, University of Calgary, Calgary, Alberta, Canada

Email address:

lee@ucalgary.ca

To cite this article:

Tang G. Lee. Converting Volatile Organic Compounds to CO₂ and Water. *American Journal of Chemical Engineering*. Vol. 4, No. 2, 2016, pp. 62-67. doi: 10.11648/j.ajche.20160402.16

Received: May 5, 2016; **Accepted:** June 2, 2016; **Published:** June 7, 2016

Abstract: This paper discusses a novel method to clean VOC from any sources. Photocatalysis surpasses any other technologies in air purification for absorption of volatile organic compounds. A key component is the use of ultraviolet light to activate a photo-catalysis process that can also disinfect microorganisms including bacteria, viruses, moulds and even infectious diseases. The by-products of the photocatalytic process is only carbon dioxide and water. Results as tested by the Chinese government agency for its VOC removal efficacy at several factories is most encouraging. In conclusion, we have found a technology that can help clean the increasing air pollution in China to improve public health.

Keywords: Air Pollution, Disinfection, Photocatalysis, Air Cleaning, By-Products, Volatile Organic Compounds

1. Introduction

In western cities, the average person's respiratory system has to eliminate, every day, over 15 ml of particulate matter including dust, pollen, tar, acids, smoke, bacteria, carbon, metals and many other particles. The air quality of Beijing is 16 times worse than New York City and can soar to 40 times the International Safety Standard [1] [2]. The results showed that ambient air pollution had acute and chronic effects on mortality, morbidity [3], hospital admissions, clinical symptoms, lung function changes, and even cancer. The exposure-response relationship between air pollutants and daily mortality, morbidity, hospital admissions, and lung function has been established accordingly [4].

In a recent report of February 2016 from the Royal College of Physicians [5], entitled, "Every breath we take - The lifelong impact of air pollution" states the following.

"4.3 million people die annually from household air pollution, around 3.3 million of whom live in Asia. The major causes of these deaths are stroke, ischaemic heart disease, chronic and acute lung disease, and lung cancer. WHO estimates that 3.7 million people die annually from ambient air pollution, again most of whom (2.6 million) live in Asia. The ranking of causes of deaths remains broadly similar. Most of those at risk of ambient air pollution live in urban settings."

"This damage occurs across a lifetime, from a baby's first weeks in the womb all the way through to the years of older age."

"Harm to babies and children will have an impact that lasts far into the future. For the same reason, any air quality improvements we make now will have long-lasting benefits."

"Older people, and adults with long-term conditions, are also vulnerable to the effects of air pollution."

The body automatically copes with such foreign matters by increasing blood flow, increasing air intake, tearing and sneezing, thus decreasing the person's alertness and efficiency. The economic costs of the health damage due to particulate air pollution in urban areas of Shanghai in 2001 was approximately 625.40 million US dollars, accounting for 1.03% of gross domestic product of the city [6]. Thus any means to clean the air has direct health and economic benefits.

2. Technologies for Removing VOC

VOC are a volatile organic compound. VOC emission control technologies include activated carbon adsorption, absorption, combustion, photocatalytic oxidation, condensation, biological treatment, etc. Common technologies for removal of VOC in waste gas treatment include the following:

2.1. Adsorption Method

Adsorption using certain substances such as activated carbon, silica gel, zeolite, activated alumina, or any porous

materials with adsorption properties such that it can eliminate harmful pollution. Microporous and mesoporous materials have been widely used in the adsorption process. However, the most commonly is activated carbon, silica gel and molecular sieves. Unfortunately these materials have low adsorption capacity, become saturated and require frequent replacement. They are also issues of flammability and other problems associated with regeneration.

2.2. Solvent Absorption Method

Liquid solvent as absorption agent converts harmful gasses using liquid absorption, to render them benign. This type of process for gaseous pollutants can handle gas flows at 3000~15 000 m³/h. VOC removal rate can reach 95%~98%, for concentrations of 0.05%~0.5% (volume fraction).

There are still shortcomings including high capital and operating costs, complexity and limited efficacy to some organic components. It is not ideal since it is prone to secondary pollution.

2.3. Thermal Destruction Method

Heat damage by direct combustion method, catalytic combustion method and concentrated combustion method. The failure mechanism is thermal cracking and oxidation, thermal decomposition, so as to achieve the objective of controlling VOCs. Thermal destruction method for small volume, high concentrations of gases, for the continuous emission of gases, using simple equipment, low investment, easy to operate, covering an area of less, recycled energy, gas cleaning thoroughly. But by combustion and explosion dangerous heat, heat, burning fuel consumption, not recycled solvents.

2.4. Biological Treatment

Biological treatment technology for waste gas treatment is an emerging technology. Common biological treatment processes include biological filtration, biological trickling filtration, biological cleaning method, membrane bioreactor and method of rotating disc bio-filter reactor.

Biofilm is the use of microbial metabolic processes on a variety of organic and some inorganic biodegradable, generates CO₂ and H₂O. It can be effective in removal of contaminants from industrial emissions. This method is simple, low operation and maintenance costs, and no secondary pollution. But removal efficiency is poor and requires long retention time. Results varies for complex composition of exhaust gases.

2.5. Photocatalysis

Photochemistry is chemical reactions induced by electromagnetic radiation (usually "light"). Where the induced reactions involve a "light-activated" catalyst, the process is called "photocatalysis". Photosynthesis (the process by which plants use sunlight to convert carbon dioxide and water into complex carbohydrates and oxygen), is a natural photocatalytic process (figure 1). During the

1980's and 1990's intensive scientific and commercial activity followed the discovery that ultraviolet light shining on photocatalytic materials produced free-radical species and positively charged "holes" at the photocatalyst surface that aggressively and efficiently destroyed organic molecules, converting them into carbon dioxide and water (the reverse of photosynthesis). This process is commonly called photocatalytic "oxidation" or "PCO" even though both oxidation and reduction occur. The efficiency of the PCO process is dependent upon (a) the wavelength and intensity of the UV light, and (b) the surface area of photocatalyst exposed to the UV light. Specific titanium dioxide has strong photo catalyst reaction. It has strong oxidation and decomposition strength.

Fig. 1. Photocatalytic process as compared to photosynthesis.

Certain wavelengths of light shining on a semi-conductor surface can also free electrons from the surface to participate in pollution scavenging (free-radical scavenging). Titanium dioxide, TiO₂, is one such semi-conductor. Among the many semi-conducting materials, TiO₂, is most extensively used because it has the advantages of low cost, abundance, chemical inertness, ease of manufacture and processing, and excellent photocatalytic activity in the UV region of the electromagnetic spectrum. Titanium is the eighth most abundant element in the earth's crust. Annual production of titanium dioxide is approximately 2 million tonnes, for use as a benign colourant in food, cosmetics, toothpaste, paint, paper, and plastics. The World Health Organization and the US Environmental Protection Agency consider the toxicity and epidemiology of exposure to titanium dioxide to be minimal [7]. There are no negative health concerns.

3. Photo-Catalysis for Removing VOC

Wide-area applications of photocatalysis are reported to reduce airborne nitrogen oxides (NO_x's) by up to 60% and volatile organic compounds (VOCs) by up to 80% in treated areas [8]. A major source of urban air pollution is vehicular exhaust [9]. Photocatalytic reactor system can operate for years with much less operator intervention and expense than filter systems, discussed above.

3.1. Preliminary Laboratory Results of Photocatalysis

Laboratory testing for Total Volatile Organic Compounds (TVOC) using acetone removed 99% of the acetone within

90 minutes (figure 2), and 99% of isopropyl alcohol in 120 minutes (figure 3) [10].

Fig. 2. TVOC – Acetone.

Fig. 3. TVOC – Isopropyl Alcohol.

3.2. Results of Photocatalysis Treatment in a Paint Shop

We conducted a photocatalytic oxidation project (a partnership R&D between China and Canada, CanChi Envirotech Inc.) in China where a prototype unit was brought to determine the removal rate of VOC emissions from a Volkswagen painting and baking chamber (figure 4).

Testing was done on Friday Nov 27, 2015 and the results came back from the government testing agency on Friday December 4, 2015.

Fig. 4. Removal of VOC in a paint chamber.

With one pass-through the prototype unit, the test results for upstream (input) and downstream (output) of the prototype test unit, and the calculated removal efficiency is seen in Table 1.

Table 1. Test results with one pass-through of the prototype unit.

VOC	INPUT mg/m ³	OUTPUT T mg/m ³	REMOVAL EFFICIENCY
benzene	0.553	0.458	18%
methylbenzene	1.028	0.989	4%
xylene/ dimethylbenzene	45.1	37.2	18%
non-methane hydrocarbons	32.0	10.6	67%
TVOC	264	120	55%

The by-products of this treatment is carbon dioxide (CO₂) and water vapour. The amount of what is important is to meet the air quality standard of China for emissions. The target concentration for VOC emissions are as follows.

Benzene >1 mg/m³

Toluene + xylene < 18 mg/m³

Non-methane hydrocarbons < 120 mg/m³

TVOC < 90 mg/m³

Post treatment of VOC emissions from our prototype meet the China air quality standard except for xylene that need about 5 more treatments. TVOC will require one additional treatment. Each treatment can be achieved by another pass through the photocatalysis unit. Recirculation is not possible since direct exhaust and 100% make-up air is required in this paint shop. Thus several treatments in series is possible (figure 5).

Fig. 5. Five slots for photocatalysis media positioned in series for multiple treatments.

3.3. Pre-filtration to Ensure Performance Efficacy

Crucial to the performance efficacy of photocatalysis is the catalytic reaction when UV light is incident on the TiO₂ coating on quartz fibres. The design parameter is to ensure UV light is not shaded from particulates being drawn through the treatment unit. Particulate filter must be installed upstream of the photocatalytic media. Typically MERV 14 is recommended to ensure fine particulates do not clog up the photocatalytic media. MERV 14 removes 75%-85% of particles with an arrestance rate of 98%. The Dust-Spot efficiency is 90%-95%. Higher efficiency air filter would be better but this will result in increased static pressure.

4. Photo-Catalysis for Disinfection

When photocatalyst is exposed to light in the presence of water vapour, two highly reactive substances are formed: hydroxyl radicals [OH] and a superoxide anion [O₂⁻]. It allows the oxidation of airborne VOCs and toxic organic matter into carbon dioxide (CO₂) and water at room temperature with UV or near-UV light source. Using short-wave ultraviolet (UV) radiation with a peak at 254 nm (UVC) for the photocatalysis also serves as germicidal action. A dosage of 3,000 microWatt-seconds/cm² is sufficient to kill/deactivate up to 90% of many common microbes [11].

Many variables in a real world environment complicate calculation and meaningful measurement of effective ultraviolet germicidal irradiation (UVGI) dosages for

microorganisms (e.g., variables include air flow, humidity, intensity and wavelength of UV light, and exposure time). However, germicidal UV light (e.g., of wavelength 253.7 nanometers in the germicidal UV-C band) will progressively kill any DNA-based organism given enough cumulative dosage.

An experiment was conducted to determine the kill rate for various exposure times to UV light for three fungi species. Figure 6 shows that 75% and 80%-95% of the fungi were killed after 5 and 10 seconds respectively [12]. Laboratory test for bacteria using *Escherichia coli* removed 97% of the airborne microbial pollutants within 120 minutes (fig. 7). The photocatalysis technology acts like a “lightning strike” at the molecular level (nanoscale), destroying both microbes and odours (not “trapping” like filters).

Fig. 6. Results of UV exposure time on kill rate of three fungi species.

Fig. 7. Total bacteria count – *Escherichia coli*.

5. Combining the Technologies

Fig. 8. Installation of the air purification unit for an office.

Fig. 9. Air purification unit scaled up for large volume air intake.

There are many sources of VOC emissions in indoor spaces such as from paints, finishes and furnishings. Characterisation of VOC emission from building contents have been studied [13]. Having a portable air purifier in a room is insufficient because occupants require outdoor air that brings in necessary oxygen. But the outdoor air is polluted and must be cleaned before brought inside. The

aforementioned technologies (particulate filtration, photocatalysis media, and UV disinfection light) are brought together in several prototype units for testing its efficacy (figure 8) and installation (figure 9). The air purification unit can be scaled up to almost any size for whole building [14]. Future papers will discuss the results of testing these combined technologies and the potential synergetic relationships between them. Other studies found a nano-catalyst filter coated with manganese oxide-based nano-catalyst removed 100% of particle substances of cigarette smoke, such as nicotine and tar, converting those into water vapour and carbon dioxide. They also suggest great potential for converged with other technologies. [15]

6. Conclusion

The results of our testing is encouraging as the Central Chinese Government set a VOC limit for factory emissions and for offgassing of solvent-containing products. An environmental tax will be applied to VOC emissions such as coatings over this VOC limit. Different products with different VOC limits will be classified. There will be great demand for removal of VOC emissions.

An air purification unit that combines particulate filtration, VOC absorption, and germicidal properties using photocatalysis has proven effective in cleaning outdoor air brought inside or removing indoor air contaminants. Photocatalysis surpasses any other technologies in air purification (Table 2). Whereas other air purification technologies can remove air contaminants, there are waste by-products and replacement of the media. Activated charcoal is widely used but it quickly becomes saturated and must be replaced. Activated charcoal can be regenerated by baking off the VOC, but this process merely transfer the VOC that is captured by the activate charcoal to another location. The primary advantage of photocatalysis is that the by-product are benign and no waste as it converts the VOC contaminants to only carbon dioxide and water vapour.

One study found some air purifiers using photocatalytic oxidation may emits formaldehyde [16]. But our instruments do not detect any formaldehyde by-product.

Table 2. Comparing the air removal efficiencies of various technologies compared to photocatalysis.

	HEPA Filter	Electro-static	Ozone	UV	Photo-catalysis
Mould	Poor	Good	Good	Good	Excellent
Bacteria	Poor	Good	Good	Good	Excellent
Dust Mites	Poor	Poor	Poor	Good	Excellent
Gasses	Poor	Poor	Good	Good	Excellent
Odours	Poor	Good	Good	Poor	Excellent
Smoke	Good	Good	Good	Poor	Good
VOCs	Poor	Poor	Good	Good	Excellent
Pet Dander	Good	Good	Good	Good	Excellent
By-products	Replace-ment	Cleaning	O ₃		CO ₂ + H ₂ O

Acknowledgements

Sponsored by The State Laboratory of Sub-tropical Architecture, South China University of Technology, Guangzhou, China.

Design, manufacturing and prototype in-house testing by CanChi Envirotech Inc, a consortium partnership between Canada and China.

References

- [1] <http://www.dailymail.co.uk/news/article-2558548/Air-pollution-Beijing-city-uninhabitable-human-beings-according-environmental-study.html>
- [2] http://www.huffingtonpost.com/2013/10/21/super-smog-beijing-china_n_4134226.html
- [3] Minsi Zhang, Yu Song and Xuhui Cai. A health-based assessment of particulate air pollution in urban areas of Beijing in 2000–2004. *Science of the Total Environment* 376 (2007) 100–108.
- [4] Bingheng Chen, Chuanjie Hong, Haidong Kan. Exposures and health outcomes from outdoor air pollutants in China. *Toxicology* 198 (2004) 291–300.
- [5] Royal College of Physicians. *Every breath we take: the lifelong impact of air pollution*. Report of a working party. London: RCP, 2016. Royal College of Pediatrics and Child Health, February 2016
- [6] Haidong Kan, Bingheng Chen. Particulate air pollution in urban areas of Shanghai, China: health-based economic assessment. *Science of the Total Environment* 322 (2004) 71–79.
- [7] (a) *Titanium Dioxide: Inhalation Toxicology and Epidemiology*, Paul M. Hext, John A. Tomenson, and Peter Thompson, *Annals of Occupational Hygiene*, March 24, 2005, 49 (6), 461–472. (b) *Titanium Dioxide: Exemption from the Requirements of a Tolerance*, U.S. Environmental Protection Agency, March 25, 1998.
- [8] *Photocatalytic Coating on Road Pavements/Structures for NO_x Abatement*, Lamar University, December 12, 2005 (and references therein). See <http://files.harc.edu/Projects/JointCenter/Meetings/RR200512/ProjectPhotocatalyticCoating.pdf>
- [9] (a) *Unique project highlights effective ways to reduce vehicle emissions*, CASA News Release - vehicle emissions study, October 12, 2006. *Don't Drive and Breathe*, Bob Weinhold, *Environmental Health Perspectives*, V 109, n. 9, September, 2001. *Understanding Air Pollution Near Urban Roadways: A Research Study*, EPA research highlights, EM magazine, p. 30, December 2006.
- [10] Air Quality Assessment for Mr. Seck Hong Chee's *Healthcare Cum Illumination Device at Tras Trading Sitting Room*. Analytical Laboratories (Singapore) Pte. Ltd. May 18, 2010.
- [11] E. David Day, Morpheic Envirotech, *MorphAir 36W Photocatalytic UV Air Purifier*, Owner/Operator Manual. Morpheic Envirotech Inc., Calgary, 2011, P. 2.
- [12] Conducted by: Professor Tang Gim Lee, The University of Calgary, in the laboratory of Bio-chem Consulting Services (1980) Ltd., Calgary, April 1, 2001.
- [13] Wang, HaiLin, Nie, Lie, Li, Jing, et al. *Characterization and assessment of volatile organic compounds (VOCs) emissions from typical industries*, *Chinese Science Bulletin*, *Environmental Chemistry*, Vo. 58, No. 7: 724–730, March 2013.
- [14] Air purification units by Dexon Canada Air Systems Inc. Calgary, Alberta Canada. <http://www.dexoncanada.com/>
- [15] Jongsoo Jurng, *Nanometer catalyst cleans up bad cigarette smoke in smoking room*. KIST Project Management Team, #2745, *Korea Institute of Science and Technology* 2015-07-08.
- [16] Lexuan Zhong, Fariborz Haghighat. *Photocatalytic air cleaners and materials technologies – Abilities and limitations. Building and Environment*, 2015; 91: 191 DOI: 10.1016/j.buildenv.2015.01.033.