Composite Reliability Index of Practical Distribution Network with PVDG Integration

Thin Thin Moe*, Myint Thuzar

Department of Electrical Power Engineering, Mandalay Technological University, Mandalay, Myanmar

Email address:

moethinthin@mtu.edu.mm (T. T. Moe)

*Corresponding author

To cite this article:

Thin Thin Moe, Myint Thuzar. Composite Reliability Index of Practical Distribution Network with PVDG Integration. *Science Journal of Circuits, Systems and Signal Processing*. Vol. 8, No. 1, 2019, pp. 24-31. doi: 10.11648/j.cssp.20190801.14

Received: July 1, 2019; **Accepted:** July 23, 2019; **Published:** August 8, 2019

Abstract: The benefits of the photovoltaic distributed generation (PVDG) installation in the distribution network include the total system loss reduction, voltage profile improvement and the reliability enhancement of the distribution network by minimizing the interruption and duration time to customers due to the loss of utility or due to the faults in transmission lines/equipments. In this research, the optimal size of PVDG is connected at the optimal location of practical distribution network (town pyone feeder). The multi-state model is used to calculate the probabilities of the solar irradiance data and the output power of PVDG. These probabilities of solar irradiance are applied to assess the reliability of the practical distribution network with PVDG integration. The reliability within the island operation mode of the distribution system with PVDG is presented. Analytical approach is described to assess the impact of PVDG on the system reliability due to the stochastic behavior of PV output power. A composite index organizing the impact of PVDG on the overall reliability of distribution network including interruption frequency, interruption duration and expected energy not supplied is presented. The results show that the integration of PVDG placement in the practical distribution network can improve the reliability and the applying proposed methodology can enable determining PVDG configuration concerning the overall system reliability improvement.

Keywords: Composite Index, Multi-State Model, PVDG, Reliability

1. Introduction

The integration of renewable DG units into a conventional distribution system depends on the power output of the DG units, availability of wind speed and solar irradiance based on the specifications of the original equipment manufacturers, repair time, configuration of the network, consumer load demand, etc. The installations of DG in electric power systems have been known to have several impacts on the systems. Those impacts include system losses, voltage regulation, power quality, and protection scheme and system reliability. Distribution system reliability can be defined as the probability of the distribution system to provide continuous power without failure for a specific period of time [1]. It has been reported in the literature that more than 80% of all customer interruptions occur due to failures in the distribution system [2].

Some researchers have been presented on the reliability assessment of distribution system with renewable dg.

Distributed generator placement is presented for loss reduction and reliability improvement [3]. The reliability of a microgrid containing prioritized loads and distributed res through a hybrid analytical-simulation method is described in [4]. Multi-state model of PV output power is researched to study the reliability of the distribution system with renewable energy resources. The island mode of distribution system with dg is researched and the probability of island successful operation is based on the dg model and load model [5]. Reliability evaluation of distribution network with DG is considered the reliability of protective devices affected by superconducting fault current limiter (sfcl)[6]. A new composite index of reliability aspects of integration of dg into the industrial networks is proposed in [7].

In this research, the reliability indices of each load point within island operation mode are proposed by installing PVDG in practical distribution network. Besides, a set of indices representing impact of PVDG on the interruption frequency, interruption duration and expected energy not supplied to every load point within island mode is represented.

A composite index is presented to describe the impact of PVDG on the overall reliability of distribution network including interruption frequency, interruption duration and expected energy not supplied.

The objective of this research is to assess the overall system reliability in the practical distribution network with the impact of PVDG. The rest of this paper is organized as follow. Methodology including photovoltaic output power model and reliability evaluation is explained in section 2. Section 3 demonstrates the case study network and its description while the results and discussion are expressed in section 4. Finally, section 5 concludes this paper.

2. Methodology

In this section, analytical approach is applied to evaluate the reliability of practical distribution network with optimal PVDG. The optimal location and PVDG size is expressed in [8] and is installed in a practical distribution network. PV output power has significantly changes with the solar irradiance data.

2.1. Photovoltaic Output Power Model

The PV output power is uncertain because of the random behavior of solar irradiance. Thus, multi-state model is necessary to reflect the output power level of PVDG. The PV output power depends on solar irradiance and is calculated using the historical data within one year in [10, 11]. The probability of solar irradiance is obtained by counting the number of hours per year for each state of solar irradiance and dividing it by total number of hours per year [12, 15]. The PV output power of solar irradiance can be calculated by using the

multi-state model referred to in [9, 14].

$$P_{PV} = \begin{cases} P_{sn} \times \frac{G_{bi}^2}{G_{std} \times R_c} & , 0 \leq G_{bi} < R_c \\ P_{sn} \times \frac{G_{bi}}{G_{std}} & , R_c \leq G_{bi} < G_{std} \\ P_{sn} & , G_{bi} \geq G_{std} \end{cases} \quad (1)$$

Where, P_{PV} is the power output of the solar cell (W); G_{bi} is global solar irradiance (W/m^2); G_{std} is the solar irradiance in a standard environment set as $1000 (W/m^2)$; R_c is a certain irradiation point set as $150 (W/m^2)$; and P_{sn} is equivalent rated capacity of PV (W). According to the output power characteristics and the historical solar irradiance, the output power state and corresponding probability of PVDG are expressed in [11].

2.2. Customers Based PV Output Power

The reliability of the distribution network with PVDG depends on the number of customers which the PV output power can supply each load point. Table 1 describes the customer data and average load within island operation mode. The relationship of the number of customers and PV output power is illustrated in figure 1.

For example, it is assumed that the output of PVDG within island operation mode is 500 kW and then, PVDG can supply reliable electric energy in lp21 and lp22. However, lp20 cannot be supplied all from PVDG in spite of the excess electric energy, i.e., 20 kW.

Figure 1. Number of customers depending on the output of PVDG.

Table 1. Customer data within island operation mode.

load point	number of customers	average load (kW)
lp19	150	160
lp20	150	160
lp21	80	128
lp22	124	252
lp23	452	504
lp24	2	412
lp25	134	252
lp26	173	252
lp27	111	260
lp28	95	252
lp29	203	252
lp30	135	252
lp31	33	160
total	1842	3296

2.3. Reliability Evaluation Technique

When a failure occurs in the network, the island operation mode is formed in the distribution system with PVDG. PVDG can supply for the load point within the island, reducing the failure rate and outage time. The reliability indices of the distribution system are an important criterion and basis for measuring system reliability [4-5 and 7], which can be usually divided into two levels: load point reliability indices and system reliability indices. The load point indices of each load point are expressed as;

$$\lambda_i = \sum \lambda P_s^i + (1 - P_s^i) \lambda'_{up} \quad (2)$$

$$U_i = \sum U P_s^i + (1 - P_s^i) U'_{up} \quad (3)$$

Where, p_s^i is the probability of PVDG output power supplying load point i , λ_i and U_i are the failure rate and annual outage time of load point i , respectively. λ and U are the failure rate and annual outage time of network components that results in interruption at load point i . λ'_{up} and U'_{up} are the failure rate and annual outage time of upstream network.

Some reliability indices include the system average interruption index (SAIFI), the system average interruption duration index (SAIDI), the customer average interruption duration index (CAIDI) and the expected energy not supplied (EENS) index. These indices can be expressed as follows:

$$SAIFI = \frac{\sum \lambda_i N_i}{\sum N_i} \quad \text{interruptions/customer-year} \quad (4)$$

$$SAIDI = \frac{\sum U_i N_i}{\sum N_i} \quad \text{hr/customer-year} \quad (5)$$

$$CAIDI = \frac{SAIDI}{SAIFI} \quad \text{hr/customer interruption} \quad (6)$$

$$EENS = \sum L_{avg(i)} U_i \quad \text{MWh/year} \quad (7)$$

where, N_i is the total number of customers at load point i , $L_{avg(i)}$

is the average load connected to the load point i and U_i is the annual outage time for each load point.

A set of indices representing the impact of PVDG on the reliability is presented in [7]. The impact of PVDG on the system average interruption frequency index (SAIFI) of every load, IG_{SAIFI} is expressed as:

$$IG_{SAIFIj} = \frac{SAIFI_j^i - SAIFI_j}{SAIFI_j} \times 100\% \quad (8)$$

where i is an index of PVDG configuration, which is determined by number, site and sizes of connected PVDG, network topology and applied protection scheme, j is a customer point. $SAIFI_j$ is average interruption frequency index at customer point j in the passive network and $SAIFI_j^i$ is average interruption frequency index at the customer point j in the configuration i of the active network.

The index IG_{SAIFIj} represents the relative increase (positive value) or decrease (negative value) of the system average interruption frequency index (%) of each customer load point, due to the operation of PVDG [7].

To evaluate an impact of single PVDG or particular PVDG configuration on the system average interruption duration index (SAIDI) of every customer point, an index IG_{SAIDI} is described as:

$$IG_{SAIDIj} = \frac{SAIDI_j^i - SAIDI_j}{SAIDI_j} \times 100\% \quad (9)$$

Where, $SAIDI_j$ is average interruption duration index at customer point j in the passive network and $SAIDI_j^i$ is average interruption duration index at the customer point j in the configuration i of the active network. Due to the operation of PVDG, the relative increase (positive value) or decrease (negative value) of the system average interruption duration index (%) of each customer load point is presented by the index IG_{SAIDIj} .

An index IG_{CAIDI} can be expressed the impact of PVDG on the customer average interruption duration index (CAIDI). Since CAIDI can be evaluated as the ratio $SAIDI/SAIFI$, IG_{CAIDI} is not introduced. The impact of each PVDG or PVDG configuration on the expected energy not supplied (EENS) of each customer point is evaluated as:

$$IG_{EENSj} = \frac{EENS_j^i - EENS_j}{EENS_j} \times 100\% \quad (10)$$

where, $EENS_j$ is the expected energy not supplied to customer point j in the passive network (kWh/yr), and $EENS_j^i$ is the expected energy not supplied to the customer point j in the configuration i of the active network (kWh/yr). The index IG_{EENSj} represents the relative increase (positive value) or decrease (negative value) of the expected energy not supplied (%) of each customer load point, due to the operation of PVDG.

In addition, a composite index is considered to assess the impacts of each PVDG or PVDG configuration on the

interruption frequency, interruption duration and expected energy not supplied [7]. To obtain the accurate reliability assessment of the distribution network with PVDG integration, a composite index, IG is proposed as:

$$IG_i = \frac{1}{100N} \left[\sum_j^N IG_{SAIFIij} + \sum_j^N IG_{SAIDIij} + \sum_j^N IG_{EENSij} \right] \quad (11)$$

The composite index is a sum of average values of positive and negative impacts of PVDG on the three independent reliability indices SAIFI, SAIDI and EENS to the customers due to PVDG operation. A potential of each PVDG or a specific PVDG configuration can be known using the composite index IG for the reliability improvement in the distribution network. The optimal PVDG configuration is the one with the minimum value of index

IG for the reliability improvement in the distribution network.

3. Case Study Network

The distribution network is 10 MVA and the total connected load on this system is 9610 kVA. In the practical distribution network, this feeder composed of 38 load points and there are five types of customers including residential, commercial, industrial, government/institution and small user. The total number of customers of town pyone feeder is 3987 [13]. The required data and information for one year from january 2018 to december 2018 are collected from mandalay electricity supply coporation (MESC) [13]. The single line diagram of town pyone feeder from owebo substation is shown in figure 2.

Figure 2. Single line diagram of town pyone feeder.

The requirement data for distribution system reliability parameters such as failure rates, repair times and switching times for transformers, breakers and lines are described in table 2. In this paper, the fuses and disconnects are assumed to be 100% reliable, i.e., the substation is fully reliable.

Table 2. Reliability parameters of practical distribution network.

components	total failure rate, λ_r (f/yr.km)	active failure rate, λ_a (f/yr.km)	repair time, r (hr)	switching time, s (hr)
transformer (11/0.415 kv)	0.015	0.015	200	1
breakers (11 kv)	0.006	0.004	4	1
line (11 kv)	0.04	0.04	20	1

The reliability of the distribution system is assessed by integrating PVDG in the practical distribution network. Figure 3 illustrates the single line diagram of town pyone feeder with PVDG integration.

Figure 3. Single line diagram of town pyone feeder with PVDG integration.

The reliability evaluation is performed on the distribution network based on the following two configurations:

1. Passive network (without PVDG)
2. Active network

The installed capacity of PVDG1 and PVDG2 are 1mw and 1.5mw, respectively. The failure rate and average repair time of PVDG are 0.1 f/yr and 18.25 h, respectively.

4. Results and Discussion

In this study, the town pyone feeder is firstly treated as passive radial while in the second, the network is considered as active one, consisting of the optimal placement of PVDG. In this research, analytical technique is applied to get optimal location of PVDG. Newton-raphson power flow solver in matlab r2014 is used to run the load flow and find the optimal location and size of PVDG. In town pyone feeder, the best locations are bus 31 and bus 37 where, the total power losses reduced to 0.457 MW and 0.51 MW, as [8]. PVDG is installed in bus 31 and bus 37. The reliability of each load point is described by considering the island mode operation.

4.1. Passive Network

The system reliability indices within the island operation mode before installing the PVDG are calculated using component reliability data and applying eqs. (4)-(7). Calculated index SAIFI in the basis radial is 0.751int/cust.yr, EENS is 44649 kWh/yr, and the value of SAIDI is 18.56 h/cust.yr, in table 3.

Table 3. Overall system reliability indices of passive network.

town pyone feeder	SAIFI	SAIDI	CAIDI	EENS (kWh/yr)
passive radial	0.751	13.94	18.56	44649

4.2. Active Network

In this section, the reliability of the distribution system is evaluated based on the PV output power. PVDG is installed in the distribution network and the island mode is considered as a new operation. When the failure occurs, the island operation is performed and PVDG still supply for the load point within

island mode, reducing the lp's failure rate and outage time. The reliability of each load point within the effective area of PV output power is expressed in table 4. The reliability within the island mode is calculated based on the percentage of PV output power.

The reliability evaluation is considered in the distribution network with PVDG1 island, PVDG2 island and PVDG1 + PVDG2 island. When PVDG1 is connected to the island 1, the reliability within the effective area has changes due to PVDG output power. The expected energy not supplied (EENS) in all passive radial and three conditions are shown in table 4. In the 100% of the output power in this system, when PVDG1 is connected in the island, EENS is 39585 kWh/yr, which is 11.3% more than in the passive radial. With PVDG2 connected to island mode 2, the value of EENS is 33462 kWh/yr which is the increased of 25% compared to the passive radial. Two

PVDG connected to the system (PVDG1 +PVDG2) increased the EENS for 34% compared to the passive radial. In this configuration, the load point outside the island 2 can be supplied because the output power of PVDG is more than average load within island 2.

Similarly, the value of SAIFI and SAIDI index within the island operation mode can be expressed for three conditions of PV output power. The reliability indices within island operation mode are described in table 5. In the 100% of PVDG output power, with the PVDG1 connected in the distribution network, the value of index SAIFI is improved for 16.5% (0.627 int./cus.yr. However in the presence of PVDG1, SAIDI is 11.95 h/cus.yr, which is 14.3% more than the passive radial. The reliability study is repeated by installing PVDG2 in the system.

Table 4. Expected energy not supplied (EENS) within island operation mode.

load point	passive radial	50% of PV output power configuration			75% of PV output power configuration			100% of PV output power configuration		
		PVDG1 island	PVDG2 island	PVDG1 & PVDG2 island	PVDG1 island	PVDG2 island	PVDG1 & PVDG2 island	PVDG1 island	PVDG2 island	PVDG1 & PVDG2 island
lp19	2158	2158	2158	2158	2158	2158	2158	955	2158	955
lp20	2115	2115	2115	2115	960	2115	960	955	2115	955
lp21	1651	774	1651	774	769	1651	769	764	1651	764
lp22	3318	1522	3318	1522	1512	3318	1512	1504	3318	1504
lp23	6975	6975	6975	6975	6975	6975	6975	6975	6975	6975
lp24	5619	5619	5619	5619	5619	5619	5619	5619	5619	5619
lp25	3591	3591	1824	1824	3591	1819	1819	3591	1814	1814
lp26	3613	3613	1824	1824	3613	1819	1819	3613	1814	1814
lp27	2318	2318	1158	1158	2318	1155	1155	2318	1152	1152
lp28	3568	3568	3568	3568	3568	1819	1819	3568	1814	1814
lp29	3568	3568	3568	3568	3568	3568	3568	3568	1814	1814
lp30	3722	3722	3722	3722	3722	3722	3722	3722	1927	1927
lp31	2428	2428	2428	2428	2428	2428	2428	2428	1286	1286
total	44649	41976	39934	37260	40805	38371	34327	39585	33462	28398

The value of SAIDI is increased by 24%. Besides, the index SAIFI in PVDG2 configuration is 0.566, which the increase of 24% compared to the passive radial. Two PVDGs (PVDG1+PVDG2) connected to the system increased the EENS for 34% and index SAIFI for 41% compared to the passive radial. In this configuration, the two PVDG (PVDG1 + PVDG2) are the most reliable condition compared with the other configuration. Detailed total reliability indices within island operation are presented in table 5 and all reliability indices based on the output power are also improved.

4.3. Overall System Reliability with PVDG Impact

A set of indices is represented for calculation of the impact PVDG on the reliability of the system in each customer point. Indices $IG_{SAIFIij}$, $IG_{SAIDIij}$ and IG_{EENSij} are obtained in three configuration, using eqs. (8)-(10), respectively. Under the condition for 100% of PV output power, the calculated indices $IG_{SAIFIij}$, $IG_{SAIDIij}$ and IG_{EENSij} are presented in tables 6 –8, respectively. PVDG1 connected to the island significantly decreases the SAIFI, SAIDI and EENS of the load points within the effective area of PV output power. The load points outside the island mode are ineffective reliable. Connecting

PVDG2 in the island 2 decreases the SAIFI, SAIDI and EENS in load points of the island 2. In addition, the surplus of PV output power is supplied the adjacent load points (lp30 and lp31) outside the island 2 and decreases the SAIFI, SAIDI and EENS in load point 30 and load point 31. By connecting two PVDGs (PVDG1 + PVDG2) in the system, the values of SAIFI, SAIDI and EENS are also decreased in the whole system, see table 4. Two PVDGs (PVDG1 +PVDG2) are the most effective configuration and the impact of PVDG on the reliability decreasing the SAIFI, SAIDI and EENS of load point (lp30 and lp31).

Similarly, in the 50% and 75% of PV output power, the indices $IG_{SAIFIij}$, $IG_{SAIDIij}$ and IG_{EENSij} can be calculated using eqs. (8)-(10). In this configuration, connecting two PVDGs (PVDG1+PVDG2) configuration are more reliable than the other configuration. In 75% of PV output power condition, the EENS and SAIFI decreases for 19% and 23%, respectively compared to the passive radial, (see table 5). Composite index is considered to get the accurate reliability on the impact of PVDG. Based on the impact indices from tables 6-8, the proposed composite index IG, in three case studies is calculated using eq. (10). Composite index, IG is shown in

table 9 and these indices are changing with the PV output power. The index IG can be described by a sum of increase or decrease of the interruption frequency, interruption duration

and expected energy not supplied to the load points, as shown in tables 6-8.

Table 5. Overall system reliability indices within island operation.

system reliability	passive radial	50% of PV output power configuration			75% of PV output power configuration			100% of PV output power configuration		
		PVDG1 island	PVDG2 island	PVDG1 & PVDG2 island	PVDG1 island	PVDG2 island	PVDG1 & PVDG2 island	PVDG1 island	PVDG2 island	PVDG1 & PVDG2 island
SAIFI	0.751	0.702	0.663	0.613	0.665	0.642	0.556	0.627	0.566	0.441
SAIDI	13.94	13.16	11.20	10.42	12.57	11.19	9.82	11.95	10.54	8.55
CAIDI	18.56	18.75	16.89	17.00	18.90	17.43	17.66	19.06	18.62	19.39
EENS	44649	41976	39934	37260	40805	38171	34327	39585	33462	28398

Table 6. PVDG impact on system average interruption frequency, $IG_{SAIFI}(\%)$ based the 100% of PV output power.

customer j														
i	configuration	lp19	lp20	lp21	lp22	lp23	lp24	lp25	lp26	lp27	lp28	lp29	lp30	lp31
1	PVDG1	-61	-60	-59	-60	0	0	0	0	0	0	0	0	0
2	PVDG2	0	0	0	0	0	0	-52	-52	-52	-51	-51	-49	-46
3	PVDG1+PVDG2	-60	-60	-59	-60	0	0	-52	-52	-52	-51	-51	-49	-46

Table 7. PVDG impact on system average interruption duration, $IG_{SAIDI}(\%)$ based the 100% of PV output power.

customer j														
i	configuration	lp19	lp20	lp21	lp22	lp23	lp24	lp25	lp26	lp27	lp28	lp29	lp30	lp31
1	PVDG1	-55	-54	-53	-54	0	0	0	0	0	0	0	0	0
2	PVDG2	0	0	0	0	0	0	-49	-49	-50	-49	-49	-48	-47
3	PVDG1+PVDG2	-55	-54	-53	-54	0	0	-49	-49	-50	-49	-49	-48	-47

Table 8. PVDG impact on expected energy not supplied, $IG_{EENS}(\%)$ based the 100% of PV output power.

customer j														
i	configuration	lp19	lp20	lp21	lp22	lp23	lp24	lp25	lp26	lp27	lp28	lp29	lp30	lp31
1	PVDG1	-55	-54	-53	-54	0	0	0	0	0	0	0	0	0
2	PVDG2	0	0	0	0	0	0	-49	-49	-50	-49	-49	-48	-47
3	PVDG1+PVDG2	-55	-54	-53	-54	0	0	-49	-49	-50	-49	-49	-48.2	-47

In the passive radial, the value of index IG is zero. The negative value of IG is the improvement of the system reliability. The two PVDGs (PVDG1 + PVDG2) configuration is the most reliability indices of the distribution system while the PVDG1 configuration is the worst reliable indices. In addition, the two PVDGs (PVDG1 + PVDG2) are the most

effective as regards the improvement of EENS. The specific PVDG configuration is given using the composite index for the reliability improvement in the distribution network. The optimal PVDG configuration is the most reliability improvement with the minimum value of composite index, IG.

Table 9. Composite reliability index, IG within island operation mode.

configuration	IG		
	50% of PV output power	75% of PV output power	100% of PV output power
PVDG1	-0.25615	-0.50385	-0.51692
PVDG2	-0.34692	-0.46077	-0.79615
PVDG1+PVDG2	-0.60308	-0.88769	-1.31231

According the results from table 9, the two PVDGs (PVDG1 + PVDG2) configuration has the minimum value of composite index, IG and this configuration is the most reliable. A set of index regarding with the impact of PVDG on the interruption frequency, the interruption duration and the expected energy not supplied to the load point within the ineffective area of PV output power is zero. All PVDG configurations decreased the index SAIFI, SAIDI and EENS of all load points within the effective area of PV output power. The indices SAIDI and EENS depend upon the annual outage

time. The impact of PVDG on the SAIDI and EENS of each load point has the same sign; the reliability indices are uniformly affected by the PVDG.

In the 100% of PV output power, connecting the two PVDGs (PVDG1 + PVDG2) configuration has the more obvious composite reliability index. According the above results, the composite index in PVDG1 configuration and PVDG2 configuration are -0.51692 and -0.79615, respectively. Installing optimal size and site of PVDG in the distribution network can considerably improve the system reliability in the

distribution system. Besides, the high internal failure rate and long restoration time of the distribution parameters and PVDG can badly get worse the overall system reliability.

5. Conclusion

The overall system reliability within island operation mode is presented by integrating PVDG in the practical distribution network. A set of indices ($IG_{SAIFIij}$, $IG_{SAIDIij}$ and IG_{EENSij}) including the interruption frequency, interruption duration and expected energy not supplied to each load point is reported for assessment of the impact of PVDG on the reliability in the practical distribution network. This paper proposes the analytical approach for finding the composite reliability index on the impact of PVDG. The advantage of the composite index IG comparing to the existing reliability indices is to describe the accurate overall system reliability in the practical distribution network with the impact of PVDG configuration. The composite index, IG summarizes the positive and negative impacts of PVDG on the three reliability indices such as SAIFI, SAIDI and EENS in all load points. The composite index can determine the optimal PVDG configuration regarding the improvement of overall reliability of the system. Accordingly the results, the configuration (PVDG1+ PVDG2) are the most reliability improvement with the minimum value of index IG. It is difficult to predict the reliability of the distribution network of every load point and the system reliability after PVDG connection or disconnection due to the random behavior of PV output power, numerous switching operations on a daily base and the complexity of the distribution network. The proposed methodology is to get the impact of various PVDG configurations on the reliability of the system.

References

- [1] R. Billinton and Ronald N. Allan. *Reliability Evaluation of Power System*, New York, 1996.
- [2] T. Adefarati and R. C. Bansal, "Reliability assessment of distribution system with the integration of renewable distributed generation", *Applied Energy*, vol. 185, pp. 158-171, October 2017.
- [3] P. Paliwal and N. P. Patidar, "Distributed generator placement for loss reduction and improvement in reliability", *World Academy of Science, Engineering and Technology*, vol. 4, no. 9, pp. 1409-1413, 2010.
- [4] A. A. Osama, N. Safari and C. Y. Chung, "Reliability assessment of microgrid with renewable generation and prioritized loads", *IEEE Green Energy and Systems Conference (IGSEC)*, pp. 1-6, November 2016.
- [5] C. Guoyan et al., "Reliability evaluation of distribution system with distributed generation," *Materials Science and Engineering (ICMMR)*, pp. 1-8, January 2017.
- [6] S-Yul Kim and J-O Kim, "Reliability evaluation of distribution network with DG considering the reliability of protective devices affected by SFCL", *IEEE Transactions on Applied Superconductivity*, vol. 21, pp. 3561-3569, no. 5, October 2011.
- [7] R. M. Ciric and N. L. J. Rajakovic, "A new composite index of reliability of supply in the industrial systems with distributed generation", *Electrical Power and Energy Systems*, vol. 44, pp. 824-831, September 2012.
- [8] Thin Thin Moe and Myint Thuzar, "Reliability enhancement of radial distribution system using optimal placement of PVDG", *Universal academic cluster (UAC)*, Thailand, pp. 1-6, May, 2019.
- [9] Jeongie Park, et al., "A probabilistic reliability evaluation of power system including solar/photovoltaic cell generator", *IEEE Power and Energy Society General Meeting (PES)*, pp. 1-6, July, 2009.
- [10] Thin Thin Moe, Kyaw Myo Lin, "Reliability assessment of distribution network with photovoltaic distributed generation considering multi-state model of PV capacity" *International Conference on Science and Engineering (ICSE) 2018 YTU*, Yangon, pp. 1-6, December 2018.
- [11] Prapon et al., "Assessment of solar energy potentials for the Union of Myanmar", *Silpakorn University*, Thailand, September 2009.
- [12] A. Aflleridi and R. Karki, "Development of probabilistic reliability models of photovoltaic system topologies for system adequacy evaluation" *Applied Sciences*, pp. 1-16, February 2017.
- [13] MESC, "Town Pyone distribution network data from Owebo substation", Mandalay Area, 2018.
- [14] T. Jen-Hao, S. W Luan, D. J. Lee and Y-Q Huang, "Optimal charging/discharging scheduling of battery storage systems for distribution systems interconnected with sizeable PV generation systems," *IEEE Transactions on Power systems*, vol. 28, pp. 1-6, November 2012.
- [15] R. A. Swief, T. S. Abdel-Salam and N. H. El-Amery, "Photovoltaic and wind turbine integration applying cuckoo search for probabilistic reliable optimal placement", *Energies*, vol. 11, pp. 1-17, January 2018.