A Simulation Study on the Energy Efficiency of Gas-Burned Boilers in Heating Systems

Zaiyi Liao^{1,*}, Wei Xuan²

¹Dept of Architectural Science, Ryerson University, Toronto, Canada

²Dept of Architecture, Hefei University of Technology, Hefei, China

Email address:

zliao@ryerson.ca (Zaiyi Liao), xuanwei417@163.com (Wei Xuan)

To cite this article:

Zaiyi Liao, Wei Xuan. A Simulation Study on the Energy Efficiency of Gas-Burned Boilers in Heating Systems. *International Journal of Energy and Power Engineering*. Vol. 4, No. 6, 2015, pp. 327-332. doi: 10.11648/j.ijepe.20150406.11

Abstract: The energy efficiency of gas-burned boilers in space heating systems is sensitive to how the boiler is controlled. This study is aimed to investigate how the overall energy performance of a heating system can be optimized using best boiler control scheme. This is to be achieved through experimental studies and simulation studies. This paper presents the latter. A simplified boiler is proposed and integrated in a heating system modeling platform for the simulation study. The results show that the boiler in a heating system should be controlled according to the heating load in order to achieve the highest long-term energy efficiency while maintaining desired comfort.

Keywords: Energy Efficiency, Boiler, Simulation Study, Heating Systems

1. Introduction

In common with many other types of building services equipment, boilers in heating systems are often considerably oversized in order to provide a substantial margin of capacity [1] [2] [3] [4]. As a result, most boilers can generate sufficient heating capacity but often do so inefficiently especially when they are operated under part-load [5] and controlled by conventional boiler controllers, such as thermostats and weather compensators [6]. There are a broad range of boiler controllers used in current practice to maintain a satisfactory performance of heating systems. A conventional weather compensator changes the set-point of water temperature according to the external temperature such that the system can be operated at lower water temperature when the heating load is low [6]. Liao and Parand developed a boiler controller that can measure the heating load and accordingly determine the optimal water temperature at which the boiler efficiency can be maximized whilst sufficient heat can be delivered to the building [5]. Liao and Dexter developed a novel boiler controller, referred to as Inferential Control Scheme (ICS), that varies the water temperature according to an estimate of the average air temperature in the building [7] [8] [9] [10] [11]. One of energy saving strategies employed by these boiler controllers is to maximize the energy efficiency of the boilers through

varying water temperature according to load or optimizing the mixture of oxygen and fuel, in addition to minimizing the heat loss throughout the heat distribution system and avoiding the overheating in the controlled spaces. The scientific credibility of these control techniques relies on a good understanding on how the energy efficiency of boilers is influenced and can be optimized in both short-term and long-term.

2. Boiler Energy Efficiency

It is well understood that there are at least three definitions of boiler efficiency:

- Combustion efficiency: how efficiently the combustion takes place in the burner. Higher combustion efficiency means that more heating capacity can be generated by consuming the same amount of fuel.
- Steady-state efficiency: how efficiently the heat is transferred from the combustion gases to the water when the boiler is running under full load.
- Seasonal efficiency: how efficiently the fuel is used by the boiler over the entire season.

These definitions are related with each other and equally important. However the seasonal efficiency is most important because it determines how much fuel is consumed over the entire heating season.

The seasonal efficiency depends on the steady-state efficiency, the combustion efficiency and the downtime losses that occur when the boiler is not operating. The downtime losses are affected by the boiler structure, type of application and design of the system.

The steady-state efficiency declines when the water temperature increases. This is because the temperature difference between the combustion chamber and water is higher when the water temperature is lower. In order to maximize the efficiency, it is always desirable to operate the boiler at as low a water temperature as possible, e.g. when the system is operating under part load.

A boiler continues to lose heat when it is turned off as follows:

- Radiation through the boiler shell or jacket.
- Convection between the boiler and the air that is drawn by the chimney draft and continues to flow through the boiler.

The more often the boiler cycles, the greater the downtime losses and the lower the seasonal efficiency are.

Katrakis and Zawachi studied the relationship between the seasonal efficiency and the load of a steam boiler through a field experiment [12]. They concluded that the seasonal efficiency of the boiler was highly sensitive to the control of boiler and the characteristic of the heating load. Higher seasonal efficiency can be achieved if the system is designed such that the off-cycling of the boiler is minimised.

Anglesio gives a relationship between the seasonal efficiency (η) and the load factor [13]. The load factor (L_f) is defined as the ratio of produced power (Q) to the maximum power ($Q_{\max}$) of the boiler.

$$\eta = 0.9 / (1 + 0.02 / L_f) \quad (1)$$

where: $L_f = Q / Q_{\max}$

Based on Equation 1, Cardinale and Stefanizzi investigated the seasonal efficiency of boilers when different control schemes were used to determine the water temperature [14]. They concluded that the annual distribution of the load factor

was sensitive to how the water temperature was determined.

3. Simulation Study on Boiler Energy Efficiency

An experimental study on boiler energy efficiency has been reported in [15]. This paper presents a simulation study.

A boiler model has been developed and validated using the experimental data obtained from the boiler test rig. Figure 1 shows an electronic analogue of a boiler model. The boiler model consists of five major components: the combustion and flame passage, the inner shell, the water passage, the outer shell, and the insulation. The boiler model is based on the following governing equations:

$$C_{is} \frac{dT_{is}}{d\tau} = K_{flame}(T_{flame} - T_{is}) - K_2(T_{is} - T_w) \quad (2)$$

$$C_w \frac{dT_w}{d\tau} = K_2(T_{is} - T_w) - \dot{m}_w \rho_w (T_{w_out} - T_{w_in}) - K_4(T_w - T_{os}) \quad (3)$$

$$C_{os} \frac{dT_{os}}{d\tau} = K_4(T_w - T_{os}) - K_5(T_{os} - T_i) \quad (4)$$

$$C_i \frac{dT_i}{d\tau} = K_5(T_{os} - T_i) - K_6(T_i - T_o) \quad (5)$$

The relevant parameters are: (1) The total thermal capacity of the inner shell (C_{is}), the outer shell (C_{os}), the water content (C_w), and the insulation (C_i).

(2) The thermal conductance between the flame and the inner shell (K_1), inner shell and the water (K_2), the water and the outer shell (K_4), outer shell and the insulation (K_5), and insulation and ambient (K_6).

C_{is} , C_{os} , C_w and C_i are calculated from the technical data of the boiler [7]. The value of K_1 , K_2 , K_3 , K_4 and K_5 are determined using experimental data through a commissioning procedure [7]. Then a different set of experimental data is used to validate the model. Figure 2 shows the validation results. The results show that the boiler model can accurately simulate the dynamics of the boiler.

Figure 1. Electronic analogue of the boiler model.

Figure 2 (a). Validation of the boiler model (constant inlet temperature).

Figure 2 (b). Validation of the boiler model (variable inlet temperature).

Figure 3. Distribution of the annual load factor for differently sized boilers.

Figure 4. Annual boiler efficiency for differently sized boilers at constant water temperatures.

The boiler model is integrated with a heating system simulator to investigate the long-term, or annual, boiler efficiency under different operating conditions.

Figure 3 shows the annual distribution of the load factor in systems with differently sized boilers. When the boiler is 30% oversized, the load factor more frequently falls into the low range, which, according to the results presented in Section 2, means that there is a bigger potential for improving the boiler efficiency by reducing the water temperature. This potential is much less when the boiler is 30% undersized because the load factor more frequently falls into the high range.

Figure 4 shows that the annual boiler efficiency is more sensitive to the water temperature when the ratio of the boiler capacity over the design heating load is higher. This means that more energy can be saved through appropriately controlling the water temperature in heating systems with oversized boilers. In heating systems with undersized boilers, there is a very limited opportunity for saving energy through changing the water temperature.

4. Strategies to Optimize Energy Efficiency of Boilers in Heating Systems

Both simulation and experimental results show that the boilers in heating systems can be operated more efficiently if the water temperature is reduced. However, in order to produce and deliver sufficient heating capacity to the building, the supply water temperature must be maintained above a certain minimum level, which varies with the changing weather and the use of the building. Therefore the best strategy to maintain high energy efficiency for long-term is based on the ability to detect the minimum heating requirement. We have investigated the performance of some

boiler control techniques in actual heating systems over the last ten years. These control techniques are designed to optimize the operation of the boilers in space heating systems for the best long-term energy efficiency. The objective of this field study is to find out if this has been actually achieved. The result is summarized as follows:

- Weather compensators [6] [14] [16] [17]

The importance of determining the set-point of the supply water temperature according to the varying climatic condition was first recognised in early 1980s. Linear compensations are commonly used in medium and large buildings to obviate installing many individual valves and sensors throughout the building. A weather compensator varies the set-point of the water temperature according to the outside temperature linearly.

It was believed that this compensator was able to stop excess heat loss due to open windows. Being a time-independent controller, this compensator strongly relies on good design of the heating system and accurate hydraulic balancing because it attempts to match the heat input into the system to the steady-state heating load. The control performance of this compensator is very sensitive to the commissioning, which often require extensive monitoring. Dexter investigated this problem and developed a self-adaptive weather compensator [18], which relies on on-line measurement of both the external and indoor temperature. Yet the commissioning has been proven to be a very difficult, if not impossible, procedure in practice. As a result, very few of this kind of compensator are commissioned properly [5].

- Heating load compensators [5] [19] [20]

A weather compensator does not consider the impact of the solar radiation, infiltration, internal heat gain, and variation of the desired room temperature on the heating load. All these elements are taken into account by a heating load

compensator, which can estimate the heating load and accordingly determine the optimal water temperature at which the efficiency of the boiler is maximized and sufficient heating capacity is produced.

- Inferential Control Scheme (ICS) [7] [9] [11]

An ICS controller can estimate the average room temperature of the building based on the information available to normal boiler controllers, including the solar radiation, the external temperature, and the boiler control signals. The estimated value of the average room temperature is then compared with the desired room temperature by a PI controller, which determines the best value for the water temperature set-point. A conventional ON/OFF control logic is then used to decide how the boilers should be operated.

The details of ICS have been reported in detail in other papers [7] [9] [11].

- Model-based predictive ICS [21] [22]

In practice, the overall performance of the ICS controller is sensitive to the parameters of the PI algorithm used to determine the water temperature set-point according to the desired and estimated average room temperature. The Model-based predictive ICS (MPICS) was developed to resolve this problem. It is a more robust version of ICS, meaning that it is much easier to commission and less sensitive to the varying operating conditions.

5. Conclusion

The following conclusions can be drawn:

- The energy efficiency of boilers in heating systems is influenced by a number of factors, including the boiler control strategy, the water temperature and the load factor.
- The energy efficiency of boilers declines if the water temperature increases.
- It is possible to maintain high energy efficiency when the load is low by changing the inlet water temperature appropriately. However a high water temperature is needed when the heating load is high.
- The lower the load factor, the higher the potential for improving the boiler efficiency by reducing the water temperature.
- When the boiler is oversized, there is a bigger potential for improving the boiler efficiency by reducing the water temperature. This potential is much less when the boiler is undersized.
- There are a number of boiler control schemes used in current practice to maintain high long-term energy efficiency by changing the water temperature set-point according to an estimation of either the heating load or the average room temperature in the building.

Currently the following tasks are being carried out to further investigate the problem:

- Investigating the energy efficiency of boilers in a broader range of heating systems, such as the systems with different terminal devices or distribution systems.
- Improving the accuracy of the boiler model.
- Developing a method and a system to test the

performance of boiler controllers.

Acknowledgements

The work presented in this paper was partially funded by FBE, UK (Foundation for the Built Environment). And the preparation of this paper is supported by Ryerson University, Canada.

References

- [1] ASHRAE (American Society of Heating, Ventilation and Air-conditioning Engineers), ASHRAE Handbook: Fundamentals (SI Edition), Atlanta: ASHRAE, 2013.
- [2] CIBSE (Chartered Institution of Building Services Engineers), CIBSE Guide A: Environmental Design New 2015, London: CIBSE, 2015.
- [3] CIBSE, CIBSE Guide Vol. A, The Chartered Institution of Building Services Engineers, London: CIBSE, 1986.
- [4] P. Gardner, Energy management systems in buildings, London: Energy Publications, 1984.
- [5] Zaiyi Liao and Forutan Parand, "Controller efficiency improvement for commercial and industrial gas and oil fired boilers: A CRAFT (Cooperative Research Action for Technology) project, contract JOE-CT98-7010. 1999-2001," Building Research Establishment (BRE), Watford, 2001.
- [6] Geoff Levermore, Building energy management systems: applications to low-energy HVAC and natural ventilation control, New York: E&FN Spon, 2000.
- [7] Zaiyi Liao and Arthur Dexter, "An experimental study on an inferential control scheme for optimising the control of boilers in multi-zone heating systems," *Energy and Buildings*, vol. 37, no. 1, pp. 55-63, 2005.
- [8] Zaiyi Liao, Arthur Dexter and Micheal Swainson, "On the control of heating systems in the UK," *Buildings and Environment*, vol. 40, no. 3, pp. 343-351, 2004.
- [9] Zaiyi Liao and Arthur Dexter, "A simplified physical model for estimating the average air temperature in multi-zone heating systems," *Buildings and Environment*, vol. 39, no. 9, pp. 1009-1018, 2004.
- [10] Zaiyi Liao and Arthur Dexter, "The potential for energy saving in heating systems through improving boiler controls," *Energy and Buildings*, vol. 36, no. 3, pp. 261-271, 2004.
- [11] Zaiyi Liao and Arthur Dexter, "An inferential control scheme for optimising the operation of boilers in multi-zone heating systems," *Building Services Engineering Research and Technology*, vol. 24, no. 4, p. 245-256, 2003.
- [12] J. T. Katrakakis and T. S. Zawacki, "Field-measured seasonal efficiency of intermediate-sized low-pressure steam boilers," *ASHRAE Transaction*, vol. 99, no. 2, pp. 429-439, 1993.
- [13] P. Anglesio, "Rendimento in funzione del carico di sistemi caldaia bruciatore per riscaldamento," *La Termotecnica*, vol. 10, pp. 79-90, 1982.
- [14] N. Cardinale and P. Stefanizzi, "Heating-energy consumption in different plant operating conditions," *Energy and Buildings*, vol. 24, pp. 231-235, 1996.

- [15] Zaiyi Liao and Wei Xuan, "An Experimental Study on the Energy efficiency of Gas-burned Boilers in Heating Systems," *International Journal of Scientific Research*, vol. 4, no. 11, pp. 267-269, 2015.
- [16] Chris Underwood, HVAC control systems: modeling, analysis, and design, London and New York: E&FN Spon, 1999.
- [17] John. L Levenhagen, HVAC control system, design diagrams, New York, London: McGraw-Hill, 1998.
- [18] Arthur Dexter, "Self-adaptive control of hot-water space-heating systems," in *Proceedings of IASTED*, Athens, Greece, 1983.
- [19] Surinder Jassar, Zaiyi Liao and Lian Zhao, "A Recurrent Neuro-Fuzzy System and its Application in Inferential Sensing," *Applied Soft Computing*, vol. 11, no. 3, pp. 2935-2945, 2011.
- [20] Surinder Jassar and Zaiyi Liao, "Improve the control of Residential Heating Systems," *Applied Mechanics and Materials*, Vols. 52-54, pp. 1571-1576, 2011.
- [21] Zaiyi Liao, "An inferential control scheme for optimizing the control of boilers in multiple-zone heating systems, PhD thesis," the University of Oxford, Oxford, 2004.
- [22] Zaiyi Liao and Arthur Dexter, "Model-based Predictive Control of Boilers in Hot-water heating Systems," *IEEE Transactions on Control Systems Technology*, vol. 18, pp. 1092-1102, 2010.